

Table of Contents

1	Introduction	1
1.1	Motivation.....	1
1.2	Hypothesis	2
1.3	General objective	2
1.4	Specific objectives	2
2	Theoretical Background.....	4
2.1	Power systems robustness in terms of frequency	4
2.1.1	Swing equation of synchronous generators	4
2.1.2	Traditional definition of total inertia of a power system	6
2.1.3	Typical response of power systems facing active power imbalances.....	8
2.2	Effects of a high share of CIGTs on frequency of power systems	10
2.2.1	Decreasing system inertia levels.....	10
2.2.2	Faster frequency dynamics	11
2.2.3	Increasing temporal variability of inertia levels	11
2.2.4	Spatial distribution of inertia	13
2.2.5	Techniques to deliver FFR from CIGTs.....	15
2.2.6	New definition of total inertia including FFR from CIGTs.....	16
2.3	Assessment of robustness in CIGTs-dominated power systems.....	16
2.3.1	Assessment of temporal variability of inertia.....	17
2.3.2	Assessment of the spatial distribution of inertia.....	19
2.4	Mathematical background	30
2.4.1	Frequency divider	30
2.4.2	Agglomerative hierarchical methods of cluster analysis	31
3	Methodology	33
3.1	Stage 1: Data acquisition	35
3.2	Stage 2: Identification of representative operating conditions (<i>ocs</i>)	35
3.3	Stage 3: Stability assessment.....	35

3.4	Stage 4: Identification of coherent SGs.....	36
3.5	Stage 5: Identification of coherent f-areas	40
3.6	Stage 6: Determination of f-robustness level	42
4	Study Case	48
4.1	System characteristics.....	48
4.2	Power system's dynamic model	51
4.3	Operating conditions.....	51
5	Results and Discussion	52
5.1	Tool development	52
5.1.1	Stage 3: Stability Assessment.....	52
5.1.2	Stage 4: Identification of coherent SGs	54
5.1.3	Stage 5: Identification of coherent f-areas.....	55
5.1.4	Stage 6: Determination of f-robustness level.....	61
5.2	Tool validation.....	67
6	Conclusions.....	77
6.1	Conclusions.....	77
6.2	Future Work.....	78
7	Bibliography	79